



OFFICIAL LISTING

NSF International Certifies that the products appearing on this Listing conform to the requirements of NSF/ANSI Standard 60 - Drinking Water Treatment Chemicals - Health Effects

This is the Official Listing recorded on September 8, 2010.

Clearon Corporation
95 MacCorkle Avenue Southwest
South Charleston, WV 25303
304-746-3000

Facility: Ramat-Hovav, Israel

| Chemical/ Trade Designation | Function | Max Use |
|-------------------------------------|--------------------------------------|---------|
| Bromochlorodimethylhydantoin | | |
| HALOGENE® G | Algicide Disinfection & Oxidation | 3 mg/L |
| HALOGENE® T-30 | Algicide Disinfection & Oxidation | 3 mg/L |

[CL] The residual levels of chlorine (hypochlorite ion and hypochlorous acid), chlorine dioxide, chlorate ion, chloramine and disinfection by-products shall be monitored in the finished drinking water to ensure compliance to all applicable regulations.

Facility: South Charleston, WV

| Chemical/ Trade Designation | Function | Max Use |
|---|--------------------------------------|---------|
| Sodium Dichloroisocyanurate [CL] | | |
| CDB Clearon® | Algicide Disinfection & Oxidation | 30 mg/L |
| CDB®-56 | Algicide Disinfection & Oxidation | 30 mg/L |
| ChloRun | Algicide Disinfection & Oxidation | 30 mg/L |
| Dichlor | Algicide Disinfection & Oxidation | 30 mg/L |
| Na Dichlor | Algicide Disinfection & Oxidation | 30 mg/L |
| Troclosene Solution | Algicide Disinfection & Oxidation | 30 mg/L |
| Trichloroisocyanuric Acid | | |
| CDB®-90 | Disinfection & Oxidation | 30 mg/L |
| CDB®-90 IWB Granular | Disinfection & Oxidation | 30 mg/L |
| CDB®-90 IWB Tablets | Disinfection & Oxidation | 30 mg/L |
| CDB®-90 Tablets | Disinfection & Oxidation | 30 mg/L |
| Halogene® 90 | Disinfection & Oxidation | 30 mg/L |
| Symclosene | Disinfection & Oxidation | 30 mg/L |
| TCCA | Disinfection & Oxidation | 30 mg/L |
| Trichlor | Disinfection & Oxidation | 30 mg/L |

Note: Additions shall not be made to this document without prior evaluation and acceptance by NSF International.



Trichloroisocyanuric acid

Disinfection & Oxidation

30 mg/L

[CL] The residual levels of chlorine (hypochlorite ion and hypochlorous acid), chlorine dioxide, chlorate ion, chloramine and disinfection by-products shall be monitored in the finished drinking water to ensure compliance to all applicable regulations.

NOTE: All Listed products from this facility are NSF Certified, whether or not they bear the NSF Mark.