

# MAHARASHTRA JEEVAN PRADHIKARAN WORKS DIVISION, SOLAPUR

Executive Engineer  
Maharashtra Jeevan Pradhikaran  
Divn,  
"Jeevan Bhavan", 232, Modi  
Solapur - 413 001.  
E-Mail- mipsolapur@rediffmail.com



(0217) Offi. 2311693  
Resi. 2601152  
Fax (0217) 2313387

Ref. No. 4548

Date:-4/11/2009

✓ To.  
ICL Israel

**Subject:** Permission for Extension of pilot run at Borgaon WTP and Certificate of "Satisfactory performance of "Chlorun"

Ref.- This Letter No. TBM/Borgaon/RRWSS/3620/2008 dated 12/09/2009

Dear Sir,

With reference to above letter you have installed your Potable Water Disinfection Technology-Chlorun which was conducted as a demo plant during a period of 17<sup>th</sup> January to 16<sup>th</sup> Sept.2009 to at our Borgaon Water Works.

We have received all the reports from our sub divisional office at Karmala regarding the pilot run of Chlorun. During this pilot, a dosing machine, data logger and Dulcometer were installed and 1100 kgs (22drums) of CDB 56 chemical was supplied by you. Then, under our observation, the chlorination with "Chlorun" was run for four 7 months to see the results. We tested the water samples by our OT test and your digital colourimeter and the results were attached with the report.

We have also received the comprehensive reports submitted by you giving us the chlorine levels on site, at reservoirs at 8 villages.

We studied the reports, visited the site to see the performance and analyzed Safety, Accuracy and Simplicity aspects of "Chlorun" technology.

We hereby certify that the performance of "Chlorun"- A potable Water Disinfection technology is very satisfactory.

You have given us a proposal for extending a pilot where small SSI units will be installed in four villages where we are not getting required chlorine levels due to long distance from WTP.

I hereby give you permission for the extension of pilot for 6 months.

Thanking You,

➤ (Dhoble P.N.)  
Executive Engineer  
MJP, Solapur division.